

.

---

**From:** Physical Plant CSR <custreq@facil.umass.edu>  
**Sent:** Wednesday, May 23, 2012 9:17 AM  
**To:** Hanchett, James (DPH)  
**Subject:** Phys Plant Update to WO# 12-017559-000 - 'Morrill Science Center Section I

**Work Order Number:** 12-017559-000

**Work Description:** Morrill I N236, Could you have the steam heat turned off in Morrill I. It leaks past valves and heats up our office., REQ.Jim Hanchett,@ 5452607 iNET

Please note that this work order above has progressed to the status of **Ready** - .

If you have any questions or comments please contact your Customer Service Representative: Sandra Russell (577-0412) or Justin Cobb (577-0413).

Thank you.